
From: donotreply@sdonecall.com[SMTP:DONOTREPLY@SDONECALL.COM]

Sent: Monday, November 04, 2013 3:28:41 PM

To: PUC Docket Filings

Subject: New One Call Complaint Form

Auto forwarded by a Rule

1. Action Requested By:

Complaint filed on behalf of or by: MidAmerican Energy Company

Contact Person: Silicia Boutchee

Phone: 800-275-5745 **Ext:**

Street Address or PO Box: 3500 104th St

City: Urbandale

State: IA

Zip: 50322

Fax: 515-242-3962

Email Address: Damageclaims@midamerican.com

Date: 11/4/2013

2. Action Requested Against:

Name of excavator / facility operator: Stone Hill Construction, Inc.

Phone: 507-828-0905 **Ext:**

Street Address Or PO Box: 3800 W 93rd St

City: Sioux Falls

State: SD

Zip: 57108

Fax: --

Email Address:

Is this party aware of your allegations?: Yes

Provide detail including whom you spoke with: Stone Hill Construction stated they had locates, but locates expired on 7/29/13. MEC sent invoice for damages

3. Basic Facts:

Street Address / location of alleged violation: 304 W 3rd St

City: Worthing

State: SD

Date of alleged violation: 08/06/2013

Time of alleged violation: 11:41 a.m.

Describe your allegation: Stone Hill Construction was grading the road to install storm sewer pipe and damage 1 1/4" gas line

Do you believe the alleged violation to be intentional?: No

Why or why not?: Previously called in locates- they were graded out.

4. Excavation / Locate Information:

Was a locate requested from SD One Call?: No

If a locate was requested:

Locate ticket #:

Start date and time on ticket:

Did the excavator wait until the start date / time on the ticket before commencing excavation?: No

If no, when did excavation begin (date and time)?: 08/06/2013 11:00 a.m.

Did the excavator maintain a minimum horizontal clearance of 18 inches between a marked facility and mechanical equipment?: No

Explain: Locates expired on 7/29/13 @ 9:12 AM - No locates visible on road - locates were still present at road edge

Were buried facilities exposed by hand or non-invasive equipment prior to excavation?: No

Were facilities marked?: Yes

Was the marking complete prior to the start time on the ticket?: NA

Did the excavator pre-mark with white paint?: No

Was the facility marked accurately (within 18 inches)?: Yes

Did the excavator use reasonable care to maintain locate marks for the life of project?: NA

Type of facility involved: 1 1/4" gas line

Operator of facility (if known): MidAmerican Energy Company

Operator address (Street or PO Box): 3500 104th St

City: Urbandale

State: IA

Zip: 50322

Phone: 800-275-5745

Depth of Cover: 38"

Pressure: 48#

Voltage: N/A

of cable pairs: N/A

5. Damages

Was the facility damaged?: Yes

If yes, provide detail and an estimate of damage: Total claim \$820.58 (Labor-725.60, Fleet-83.04, Material-11.94)

Were damages on public right of way or private property?: Public

Was anyone injured as a result of facility damage?: No

If yes, provide detail:

Length of hospitalization:

Were there fatalities?: No

If yes, provide detail:

Was operator service affected?: Yes

If yes, provide detail (how many customers for how long): ONE CUSTOMER AFFECTED

Other information regarding injuries or damages:

6. Statutory Violation

Specific statute(s) or rule(s) you believe were violated: 49-7A-5 & 49-7A-10

Other information to support your position: Emergency locate ticket called in Stone Hill #132180435

Attachments - Invoice & Summary, org locate ticket, Emergency ticket, photos of damages