



November 25, 2013

South Dakota One Call  
C/O Public Utilities Commission  
500 E Capitol Ave.  
Pierre, SD 57501

**RECEIVED**  
**DEC 02 2013**  
**SOUTH DAKOTA PUBLIC UTILITIES COMMISSION**

RE: OC13-029

Dear Sir,

In the matter of the complaint filed by MDU against RCS Construction for an incident occurring on October 24, 2013 at 1111 Zinc Street, Rapid City, SD.

The Superintendent on that project had requested a locate (ticket #132460006) which expired on September 26, 2013.

This gas line was excavated around numerous times during the installation of the water lines. On October 24, 2013 a different Superintendent was detailed with the task of installing a bollard on this street. He sent a crew to the jobsite with the auger and proceeded to call the previous Superintendent. Before that conversation could take place the crew had begun to auger and accidentally busted this gas line. This was due to a communication error between the Superintendent and his crew.

Please call if you have any questions. Thank you for your cooperation.

Kind Regards,

  
Jim Witt, P.E.  
Project Manager  
R.C.S. Construction Inc.  
(605) 342-3787



Safety • Quality • Communication • Timeliness

2400 Commerce Road • P.O. Box 9337 • Rapid City, SD 57709-9337

Phone (605) 342-3787 • Fax (605) 348-4041

www.resconst.com

