



INCIDENT INVESTIGATION #207660



610 Sioux Ave , Pierre, SD

LOCATION DETAILS

Event Date: 05/03/2021 12:00 PM America/Denver

Right-of-Way: Private Business

AFFECTED FACILITY

Near Miss: No

Type of Operation Affected: Gas

Line Size and Type: 1.25" Gas

Facility part of joint trench: No

Asphalt or concrete removed: No

Damage Surface Type and Depth: Dirt < 18"

Arrival Date and Time: 05/03/2021 12:09 PM America/Denver



Distance from Ped to Ped: 0ft

Dimensions of Asphalt or Concrete Removed: 0

Repairs Taking Place Upon Arrival? No

Who Performed Repairs: Utility Company

Contractor Representative: Nick Williams

Contractor Representative Phone Number: (605) 220-1714

Personnel On Site: 1 Forman and 1 technician

Vehicles/Equipment Being Used For Repairs: Hand tools

Guards or Barricades On Site: No

Facilities Replaced or Repaired: Repaired

Replacement Type: Permanent

Occurred During: Business Hours

Time Occurred:

DAMAGER

Company Name: R&w construction

Contact: Bo Atkins

Contact Phone: (605) 295-2996

Type of Work: Water and Sewer

Damage Responder: Kevin, Anderson

UTILITY INFORMATION

Utility Company Name: Montana Dakota Utilities

Utility Contact Name: Nick Williams

Utility Contact Phone: (605) 220-1714

Utility Representative: Nick Williams

Utility Rep Tech#:

Utility Rep. Present on Arrival: No

EXCAVATION INFORMATION

Excavator Type: Contractor

Excavation Equipment: Backhoe/Trackhoe

Work Performed: Sewer

Excavator downtime? No

Downtime hours: 0

Downtime cost: \$0

NOTIFICATION AND LOCATING

One Call Center notified: No

Locator Type: Facility Owner

Work area white-lined: No

Ticket Number: 2109174375

Date Located: 04/01/2021 02:36 PM America/Denver

Located By: Kevin Anderson

INTERRUPTION AND RESTORATION

Event cause Interruption: Yes

Interruption hours: 2

Customers Affected (approx.): 1

ROOT CAUSE

Root Cause: Excavator dug after valid ticket expired

COMMENTS

Assessment Comments: 1 1/4 inch gas service to new McDonald's building was hit Contractor did not have valid locate ticket for work to be done. Ticket was expired. MDU arrived on site to repair the gas service MDU has put gas service in since the 1st time locate was called in for new water line

NEW INCIDENT PHOTOS




Date: 05/03/2021 12:14 PM America/Denver

Latitude: 44.371472

Longitude: -100.360715

Heading: 13 degrees




Date: 05/03/2021 12:14 PM America/Denver

Latitude: 44.371472

Longitude: -100.360716

Heading: 6 degrees




Date: 05/03/2021 12:17 PM America/Denver

Latitude: 44.371497

Longitude: -100.360735

Heading: 341 degrees




Date: 05/03/2021 12:14 PM America/Denver

Latitude: 44.371471

Longitude: -100.360718

Heading: 155 degrees



Date: 05/03/2021 12:17 PM America/Denver

Latitude: 44.371524

Longitude: -100.360774

Heading: 87 degrees



Date: 05/03/2021 12:17 PM America/Denver

Latitude: 44.371545

Longitude: -100.360779

Heading: 38 degrees